

Serial 07028-RFI – Security Building Walk-Through Questions/Answers (03/23/07)

Q - 1. Will the HVAC load vary based on the proposed use?

A - 1 Yes! HVAC load is dependent on proposed use.

Q – 2 How does the County intend to cover the cost of the chilled water supplied to the leased space?

A – 2 Most likely will require the installation of a BTU sub-meter

Q – 3 Will the tenant be responsible for HVAC systems design and installation within the lease space?

A – 3 All design would require approval by the Maricopa County Facilities Management Department. The design is required to be consistent with existing system types and connections within our control systems.

Q – 4 Will gas and electric be separately metered?

A – 4 Yes

Q – 5 Will the CAD Files be available prior to March 20, 2007?

A – 5 CAD Files are available on the “Location” area of the site.