

Maricopa County Local Additions & Addenda

Maricopa County Planning and Development Department
501 N. 44th St.
Phoenix, AZ 85008

September 2011



Maricopa County

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Table of Contents

CHAPTER 1 – PURPOSE & TITLE		
Section		Page
101	Purpose	1
102	Title	1
103	Separability	1
104	Amendment	1
105	Revocation	1
CHAPTER 2 – ADMINISTRATION		
Section		Page
201	Definitions	1
202	Violation & Penalty - Reserved	1
203	Building Code Advisory Board - Reserved	1
204	Organization & Enforcement	1
205	Permits	1
206	Inspections	2
207	Certificate of Occupancy	3
208	Fees	3
209	Additional Regulations	8
210	Barriers for Swimming Pools, Spas & Hot Tubs	8
211	Residential Woodburning Restrictions	12
CHAPTER 3 – ADOPTION OF NATIONAL CODES		
Section		Page
301	2009 International Building Code	1
302	2009 International Residential Code	6
303	2009 International Mechanical Code	8
304	2009 International Plumbing Code	8
305	2008 National Electrical Code	8
306	Amendment to 2003 International Fire Code	13
307	2009 International Fuel Gas Code	14

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 1 – Purpose & Title

SECTION 101. PURPOSE

The purpose of this document is to provide all local addenda, amendments, and additions to the adopted national building codes in one location.

SECTION 102. TITLE

This document shall be referred to and known as "Local Additions & Addenda".

SECTION 103. SEPARABILITY

If any section, subsection, sentence clause, phrase or portion of this Ordinance is for any reason held to be invalid or unconstitutional by the decision of any court of competent jurisdiction, such decision shall not effect the validity of the remaining portions thereof.

SECTION 104. AMENDMENT

This document may be amended from time to time. It may be amended by simple motion of the Board of Supervisors, provided all state required legal advertising for amending a Building Code has been satisfied. Staff may correct typographical errors and/or reformat this document without being considered an amendment.

SECTION 105. REVOCATION

This document shall abolish, replace, and/or supercede any previous amendments, changes or additions to the national codes previously approved by Maricopa County.

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 2 – Administration

SECTION 201. PURPOSE

The purpose of this Chapter is to provide all local changes to the adopted national building codes that relate to the administration of those codes in on location.

SECTION 202. VIOLATION & PENALTY (Reserved)

SECTION 203. BUILDING CODE ADVISORY BOARD (Reserved)

SECTION 204. ORGANIZATION & ENFORCEMENT

Code Enforcement Agency

The Code Enforcement Agency created under the building code shall be defined in Maricopa County as the Planning and Development Department. This Planning and Development Department is charged by the Board of Supervisors to implement the building code and other pertinent laws, ordinances and/or regulations through the County's One Stop Shop Program.

Building Official

The Building Official shall be the Director of the Planning and Development Department (or his/her duly authorized representatives), who is charged with the administration and enforcement of the building code and Building Safety Ordinance.

General

Wherever the building code refers to the intent, purpose, implementation, inspection, enforcement, regulation, issuance of documents, compliance or other similar activity related to "this code", the phrase for purposed of implementing the "One Stop Shop Program" shall mean "this code or other pertinent laws, ordinances, and/or regulations implemented through the Code Enforcement Agency."

SECTION 205. PERMITS

Permit Expiration: A permit may be renewed within one year of expiration provided that no change in ownership or engineer/architect of record has occurred. Renewal after expiration for more than one year shall not be permitted. Any such permit shall be deemed to be revoked and a new permit must be issued.

The design and construction of structures located within the unincorporated areas of Maricopa County shall comport to the codes in effect at the time of permit application, provided the specific permit remains valid, regardless of whether or not the County adopts subsequent codes. When approved by the Building Official, utility-scale solar generating facilities in which permit

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 2 – Administration

applications have been submitted, the design and construction may continue to utilize the codes in effect at the time of initial permit application, regardless of the number of permits required to complete the project, provided that 1) all construction is covered by an issued permit, 2) any permits issued for construction remain valid; and 3) continuous construction takes place until the facility is commissioned for commercial service and the facility receives final inspection. Once the above conditions have been met, subsequent construction activity shall comply with the codes in effect at the time of subsequent permit applications. Further, should a permit lapse, the work contemplated by the permit shall be subject to a new permit application and shall comport to the codes in effect at the time the new permit application is submitted. For purposes of this section, the term "Utility-Scale" shall be as defined by the Maricopa County Zoning Ordinance.

SECTION 206. INSPECTIONS

Pre-Permit Inspection: A pre-permit inspection may be necessary and shall be the responsibility of the permit holder to post the property in a manner approved by the Building Official.

Permit Holder Responsibilities: It shall be the responsibility of the permit holder to:

1. Call for an inspection.
2. Stake property corners.
3. Designate property lines prior to the inspection of any primary use.
4. Post the inspection card.
5. Provide a copy of the approved plans on the site.
6. Provide access to the site.
7. Have someone at the site during the inspection.

Failure to complete the above shall result in no inspection at the time and an assessment of a re-inspection fee. A survey of the lot may be required by the Building Official to verify that the building/structure is located in accordance with the approved plans.

Partial Inspections: Partial inspections may be requested and conducted when necessary due to common construction practices. If a partial inspection is approved, documentation shall be maintained during construction that identifies what segments of work have obtained what types of partial inspection approval.

Re-inspections: Re-inspection fees shall apply when:

1. Property lines have not been designated as required.
2. The inspection card is not posted or available on the work site.
3. Approved plans are not readily available to the inspector on the site.
4. There is no access on the date for which the inspection is requested.
5. Work is not ready for inspection.
6. Work has been covered.

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 2 – Administration

7. Late cancellation.
8. There is a deviation from plans significant enough to require approval of revised plans.

To obtain a re-inspection, the applicant shall follow the same procedures required for an inspection after paying a re-inspection fee.

SECTION 207. CERTIFICATE OF OCCUPANCY

The purpose of a Certificate of Occupancy is to insure that all department requirements have been met. A Certificate of Occupancy is required for all permits except those issued over the counter.

Temporary Certificate: A Temporary Certificate of Occupancy may be issued with the concurrence of all impacted departments and when appropriate fees are paid. Bonding, if required, shall be provided in accordance with the direction of the Building Official prior to issuance of a Temporary Certificate.

Permanent Utility Authorization: Permanent utility approval shall not be authorized until after a permanent Certificate of Occupancy has been issued. Said authorization to the utility company shall include a copy of the Certificate of Occupancy or letter of approval.

SECTION 208. FEES

Determination of Value: Values shall be determined through the use of the most current published Building Valuation data in the publication "Building Standards" as modified for Arizona. The Building Official may develop similar increases for unpublished valuations.

Additional Value Determinations:

Walls and fences:

Retaining walls	Per lineal foot
0-2'	\$15
2-4'	\$25
4-6'	\$42
6' or more	\$86
Chain link	\$ 6
CMU	
4" 6' or less	\$14
4" more than 6'	\$21
8" block or other	\$22
Wrought iron	\$16
Iron wood	\$18
Wood	\$11
3 strand barbed wire	\$ 3
Rail	\$ 6

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 2 – Administration

In ground pools \$200 per perimeter foot

Wood frame or masonry patio covers shall be valued as open carports.

Metal patio covers and covered pipe-rail horse corrals shall be valued at 50 percent of the value of a wood or masonry patio cover.

Non-habitable accessory buildings, other than covered pipe-rail horse corrals, shall be valued as a private garage.

Water/sewer collection and distribution lines shall be valued as determined by the building official.

Shell buildings shall be valued at 80% of new building value.

Alterations shall be valued at 20% of new building value.

Processing: All plan review fees (65 percent of calculated permit fee) required to be paid shall entitle the applicant to three submissions and reviews of documents submitted. If the applicant is unable to obtain approval of his application with these three attempts, the application shall be denied. The applicant may then resubmit and the submittal shall be treated as a new application. Should these circumstances occur or the permit has been expired in accordance with the Building Code, the Building Official may use information located in the denied/expired files to expedite processing, provided that the owner and/or architect/engineer have remained the same and that the building plans have not been changed.

No subsequent step in the permit process shall be undertaken without all fees due being paid.

Fees: The Building official may develop a requirement for an initial flat rate filing fee for permits that require plan review. Should this type of fee be developed, said fee shall be considered as a part of and credited against any required plan review fees. The building plan review fees specified in the code are separate fees from the permit fees specified, these fees are also separate from the fees specified for investigations. Building plan review fees are assessed in addition to these other fees. All fees may be rounded up to the next full dollar amount at the discretion of the Building Official.

The following fees are hereby established for use.

TABLE 1-A – BUILDING CODE/PERMIT FEES

Total Valuation	Fee
\$1 TO \$500	\$23.50

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 2 – Administration

\$501 TO \$2,000	\$23.50 for the first \$500 plus \$3.05 for each additional \$100, or fraction thereof, to and including \$2,000
\$2,001 to \$25,000	\$69.25 for the first \$2,000 plus \$14.00 for each additional \$1000, or fraction thereof, to and including \$25,000
\$25,001 to \$50,000	\$391.75 for the first \$25,000 plus \$10.10 for each additional \$1000, or fraction thereof, to and including \$50,000
\$50,001 to \$100,000	\$643.75 for the first \$50,000 plus \$7.00 for each additional \$1000, or fraction thereof, to and including \$100,000
\$100,001 to \$500,000	\$993.75 for the first \$100,000 plus \$5.60 for each additional \$1000, or fraction thereof, to and including \$500,000
\$500,001 to \$1,000,000	\$3,233.75 for the first \$500,000 plus \$4.75 for each additional \$1000, or fraction thereof, and including \$1,000,000
\$1,000,001 and up	\$5,608.75 for the first \$1,000,000 plus \$3.65 for each additional \$1000, or fraction thereof

Other Inspections and Fees:

1. Inspections outside of normal business hours	\$ 150 per residential inspection \$ 250 per commercial inspection
2. Reinspection fees	\$ 150 per residential inspection \$ 250 per commercial inspection
3. Inspections for which no fee is indicated	\$ 150 per inspection
4. Expedited in-house plan review	\$ 75 per hour
5. Expedited plan review by consultant	Actual costs
6. Standard plan review (5 options)	2 times normal plan review fee
7. Change to approved plan (includes standards)	\$ 250
8. Code Modification	\$ 100 per request
9. Alternate material, design or methods	\$ 100 per request
10. Tests required	\$ 100 per test & test fees paid by applicant
11. Appeal to the Building Code Advisory Board	\$ 500
12. Amendment to the Code	\$1500
13. Requested/needed staff directive	\$ 250
14. Requested staff research report	\$ 100 residential property \$ 250 commercial property

Flat Rate Fees:

Air conditioner	\$ 50
Elec. Serv Residential 1 – 200 amps	\$ 50

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 2 – Administration

Elec. Serv Res or Comm 201 – 400 amps	\$ 75
Elec. Serv Over 400 amps	\$120
Temporary meter	\$ 50
Evaporative cooler	\$ 50
Gas Line (connect or clearance)	\$ 50
Mobile home "Pre-HUD Upgrade"	\$ 50
Plumbing sewer line SFR	\$ 50
Irrigation System	\$ 50
Sprinkler	\$ 50
Mechanical	\$ 50
Plumbing (Install or replace Equip/fixture/devices)	\$ 50
Demolition Permit	\$ 50
Manufactured/Mobile Home Setup/Installation	\$ 300
Commercial Manufactured Building (factory built building)	Based on installation value & Table 1-A
Occupancy Change	\$ 75
Hot tub or Spa (in or above ground)	\$ 75
Swimming pool above ground	\$ 75
Compliance Inspection	\$100
Move on House (compliance inspection)	\$100
Renew permit for final	\$100
Special Event Fee (tents)	\$ 100 per event

Additional Fees:

Plumbing (water/sewer collector lines)	\$ 30 min based on valuation
Amendment to approved plan data	\$ 30
Unpaved Parking Area Paving	\$100
Temporary Certificate of Occupancy	
Without bonding	\$250
With bonding	\$500
Subdivision Infrastructure Permit	\$300
Ground mounded residential solar system	\$650
Roof mounted residential solar system	\$500

Copy Charges:

Additional copy of:	
Permit	\$ 2
Job card	\$ 2
Certificate of Occupancy	\$ 2
Copy (Approved Plans – per set)	\$ 15 per set (Restamping Only)

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 2 – Administration

Copy (per page)	
Standard copier	\$ 1
Oversize copier	\$ 6

Grading Fees:

Plan Review Fees:

Volume of material (Cut and Fill)	Fee
<50 cubic yards	No fee
50 – 100 cubic yards	\$ 23.50
101 – 1,000 cubic yards	\$ 37.00
1,001 – 10,000 cubic yards	\$ 49.25
10,001 – 200,000 cubic yards	\$ 49.25 plus \$ 24.50 for each additional 10,000 cubic yards or fraction thereof
200,001 or more cubic yards	\$269.75 plus \$ 7.25 for each additional 10,000 cubic yards or fraction thereof
Additional plan review required by changes, additions, or revisions to approved plans	\$ 50.00

Permit Fees:

Volume of material (Cut and Fill)	Fee
<50 cubic yards	\$ 23.50
50 – 100 cubic yards	\$ 37.00
101 – 1,000 cubic yards	\$ 37.00 plus \$ 17.50 for each additional 100 cubic yards or fraction thereof
1,001 – 10,000 cubic yards	\$194.50 plus \$ 14.50 for each additional 1,000 cubic yards or fraction thereof
10,001 – 100,000 cubic yards	\$325.00 plus \$ 66.00 for each additional 10,000 cubic yards or fraction thereof

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 2 – Administration

100,001 or more cubic yards

\$919.00 plus \$ 24.50 for each additional
10,000 cubic yards or fraction thereof

Payment of Fees: No application shall be scheduled for hearing by any board or commission acting pursuant to the "Maricopa County Local Additions and Addenda", or administratively approved unless and until all fees and fines owed to the Department as a result of any activity or inactivity attributable to the property that is the subject of the application are brought current and paid in full or any amounts owed pursuant to an agreement of compliance are current, as the case may be. This requirement shall not be waived by the board/commission. ^{*1*2}

SECTION 209. ADDITIONAL REGULATIONS

NOISE LEVEL REDUCTION: Any building within the vicinity of a military airport or ancillary military facility as defined by State Statute shall have a noise level reduction incorporated in the design and construction of any residential building or portions of buildings where the public is received, office areas and where normal noise level is low for first occupancy, including libraries, schools and churches, pursuant to building permits issued after December 31, 2001 in order to achieve a maximum interior noise level of forty-five decibels in areas within noise contours described in Section 1007. of the Maricopa County Zoning Ordinance. All residential buildings in territory in the vicinity of a military airport but outside the noise contours as described in this section shall be constructed with a minimum of R18 exterior wall assembly, a minimum of R30 roof and ceiling assembly, dual-glazed windows and solid wood, foam-filled fiberglass or metal doors to the exterior or, if the specified building standards are not met, the County may approve as an alternative, a certification by an architect or engineer registered pursuant to A.R.S. Title 32, Chapter 1 to achieve a maximum interior noise level of forty-five decibels at the time of final construction.

SECTION 210. BARRIERS FOR SWIMMING POOLS, SPAS & HOT TUBS

SECTION 210.1 - GENERAL

210.1.1

Scope. The provisions of this section apply to the design and construction of barriers for swimming pools located on the premises of Group R, Division 3 Occupancies.

210.1.2

Standards of Quality. In addition to the other requirements of this code, safety covers for pools and spas shall meet the requirements for pool and spa safety covers as listed below. The standard listed below is a recognized standard. (See Section 3504.)

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 2 – Administration

1. ASTM F 1346, Standard Performance Specification for Safety Covers and Labeling Requirement for All Covers for Swimming Pools, Spas and Hot Tubs

SECTION 210.2 – DEFINITIONS

For the purpose of this section, certain terms, words and phrases are defined as follows:

ABOVEGROUND/ON-GROUND POOL. See definition of "swimming pool."

BARRIER is a fence, wall, building wall or combination thereof that completely surrounds the swimming pool and obstructs access to the swimming pool.

GRADE is the underlying surface, such as earth or a walking surface.

HOT TUB. See definition of "spa, nonself-contained" and "spa, self-contained."

IN-GROUND POOL. See definition of "swimming pool."

SEPARATION FENCE is a barrier that separates all doors of a dwelling unit with direct access to a swimming pool from the swimming pool.

SPA, NONSELF-CONTAINED is a hydro massage pool or tub for recreational or therapeutic use, not located in health-care facilities, designed for immersion of users and usually having a filter, heater and motor-driven blower. It may be installed indoors or outdoors, on the ground or on a supporting structure, or in the ground or in a supporting structure. A nonself-contained spa is intended for recreational bathing and contains water over 24 inches (610mm) deep.

SPA, SELF-CONTAINED is a continuous-duty appliance in which all control, water-heating and water-circulating equipment is an integral part of the product, located entirely under the spa skirt. A self-contained spa is intended for recreational bathing and contains water over 18 inches deep.

SWIMMING POOL is any structure intended for swimming or recreational bathing that contains water over 18 inches deep and/or wider than 8 feet at any point. This includes in-ground, aboveground and on-ground swimming pools, and fixed-in-place wading pools.

SWIMMING POOL, INDOOR is a swimming pool that is totally contained within a residential structure and surrounded on all four sides by walls of said structure.

SWIMMING POOL, OUTDOOR is any swimming pool that is not an indoor pool.

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 2 – Administration

SECTION 210.3 – REQUIREMENTS

210.3.1 Outdoor Swimming Pool. An outdoor swimming pool shall be provided with a barrier that shall be installed, inspected and approved prior to plastering or filling with water. The barrier shall comply with the following:

1. The top of the barrier shall be at least 60 inches above grade measured on the side of the barrier that faces away from the swimming pool. The maximum vertical clearance between grade and the bottom of the barrier shall be 2 inches (51 mm) measured on the side of the barrier that faces away from the swimming pool. The maximum vertical clearance at the bottom of the barrier may be increased to 4 inches (102 mm) when grade is a solid surface such as a concrete deck, or when the barrier is mounted on the top of the aboveground pool structure. When barriers have horizontal members spaced less than 54 inches apart, the horizontal members shall be placed on the pool side of the barrier. Any decorative design work on the side away from the swimming pool, such as protrusions, indentations or cutouts, which render the barrier easily climbable, is prohibited.
2. Openings in the barrier shall not allow passage of a 1 ³/₄-inch-diameter (44.5 mm) sphere.

EXCEPTIONS:

1. When vertical spacing between such openings is 54 inches or more, the opening size may be increased such the passage of a 4-inch-diameter (102 mm) sphere is not allowed.
2. For fencing composed of vertical and horizontal members, the spacing between vertical members may be increased up to 4 inches (102 mm) when the distance between the tops of horizontal members is 54 inches or more.
3. Chain link fences used as the barrier shall not be less than 11 gage.
4. Access gates shall comply with the requirements of Items 1 through 3. Pedestrian access gates shall be self-closing and have a self-latching device. Where the release mechanism of the self-latching device is located less than 54 inches (1372 mm) from the bottom of the gate, (1) the release mechanism shall be located on the pool side of the barrier at least 3 inches (76 mm) below the top of the gate, and (2) the gate and barrier shall have no opening greater than 1/2 inch (12.7 mm) within 18 inches (457 mm) of the release mechanism. Pedestrian gates shall swing away from the pool. Any gates other than pedestrian access gates shall be equipped with lockable hardware or padlocks and shall remain locked at all times when not in use.
5. Where a wall of a Group R, Division 3 Occupancy dwelling unit serves as part of the barrier and contains door openings between the dwelling unit and the outdoor swimming pool that provide direct access to the pool, a separation fence meeting the requirements of Items 1, 2, 3 and 4 of Section 210.3.1 shall be provided.

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 2 – Administration

EXCEPTIONS: When approved by the building official, one the following may be used:

1. Self-closing and self-latching devices installed on all doors with direct access to the pool with the release mechanism located a minimum of 54 inches (1372 mm) above the floor.
2. An alarm installed on all doors with direct access to the pool. The alarm shall sound continuously for a minimum of 30 seconds within seven seconds after the door and its screen, if present, are opened, and be capable of providing a sound pressure level of not less than 85 dBA when measured indoors at 10 feet (3048 mm). The alarm shall automatically reset under all conditions. The alarm system shall be equipped with a manual means such a touchpad or switch, to temporarily deactivate the alarm for a single opening. Such deactivation shall last no longer than 15 seconds. The deactivation switch shall be located at least 54 inches (1372 mm) above the threshold of the door.
3. Other means of protection may be acceptable so long as the degree of protection afforded is not less than that afforded by any of the devices described above.
4. Where an aboveground pool structure is used as a barrier or where the barrier is mounted on top of the pool structure, and the means of access is a ladder or steps, then (1) the ladder or steps shall be capable of being secured, locked or removed to prevent access or (2) the ladder or steps shall be surrounded by a barrier that meets the requirements of Items 1 through 5. When the ladder or steps are secured, locked or removed, any opening created shall be protected by a barrier complying with Items 1 through 5.

210.3.2 Indoor Swimming Pool. For an indoor swimming pool, protection shall comply with the requirements of Section 210.3.1 Item 5

210.3.3 Spas and Hot Tubs. For a nonself-contained and self-contained spa or hot tub protection shall comply with the requirements of Section 210.3.1

EXCEPTION: A self-contained spa or hot tub equipped with a listed safety cover shall be exempt from the requirements of Section 210.3.1

210.3.4 Where a window faces a swimming pool enclosure, said window shall be equipped with a screwed in place wire mesh screen, a keyed lock that prevents opening the window more than 4" or a latching device located not less than 54" above the floor. Emergency escape or rescue windows in bedrooms which face swimming pool enclosures shall be equipped with a latching device located no less than 54" above the floor.

2103.5 Protective enclosures shall be located at a minimum horizontal distance of 54" from any equipment, permanent structures, planters, or similar objects that could be used to climb the enclosure. This provision shall not apply to the area between the

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 2 – Administration

pool and the protective enclosure if the protective enclosure is a solid wall with no openings.

SECTION 211. RESIDENTIAL WOODBURNING REGULATIONS

211.1 FIREPLACE RESTRICTIONS

211.1.1 Purpose

The purpose of this subsection is to regulate fireplaces, wood stoves, or other solid-fuel burning devices to reduce the amount of air pollution caused by particulate matter and carbon monoxide.

211.1.2 Applicability

The Residential Woodburning Restriction Ordinance applies to any residential wood burning device in sections of Area A that are within Maricopa County or within incorporated cities and towns in such sections.

AREA A – As defined in Arizona Revised Statutes (ARS) §49-541(1), the area in Maricopa County delineated as follows:

Township 8 North, Range 5 East and Range 3 East
Township 7 North, Range 5 West through Range 5 East
Township 6 North, Range 5 West through Range 6 East
Township 5 North, Range 5 West through Range 7 East
Township 4 North, Range 5 West through Range 8 East
Township 3 North, Range 5 West through Range 8 East
Township 2 North, Range 5 West through Range 8 East
Township 1 North, Range 5 West through Range 7 East
Township 1 South Range 5 West through Range 7 East
Township 2 South, Range 5 West through Range 7 East
Township 3 South Range 5 West through Range 1 East
Township 4 South Range 5 West Through Range 1 East

211.1.3 Effective Date

The effective date of the regulations and prohibitions set forth this subsection shall be December 31, 1998.

211.1.4 Definitions

For purposes of this subsection, the following words and terms shall be defined as follows:

FIREPLACE means a built in place masonry hearth and fire chamber of a factory-built appliance, designed to burn solid fuel or to accommodate gas or electric log insert or similar device, and

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 2 – Administration

which is intended for occasional recreational or aesthetic use, not for cooking, heating, or industrial processes.

SOLID FUEL includes but is not limited to wood, coal, or other nongaseous or nonliquid fuels, including those fuels defined by the Maricopa County Air Pollution Control Officer as “inappropriate fuel” to burn in residential wood-burning devices.

WOOD STOVE means a solid-fuel burning heating appliance, including a pellet stove, which is either freestanding or designed to be inserted into a fireplace.

211.1.5 Installation Restrictions

- (a) On or after December 31, 1998, no person, firm or corporation shall construct or install a fireplace or a wood stove, and the Building Official shall not approve or issue a permit to construct or install a fireplace or a wood stove, unless the fireplace or wood stove complies with one of the following:
 - 1. A fireplace which has a permanently installed gas or electric log insert.
 - 2. A fireplace, wood stove or other solid-fuel burning appliance which has been certified by the United States Environmental Protection Agency as conforming to 40 Code of Federal Regulations Part 60, Subpart AAA as in effect on July 1, 1990.
 - 3. A fireplace, wood stove or other solid-fuel burning appliance which has been tested and listed by a nationally recognized testing agency to meet performance standards, equivalent to those adopted by 40 Code of Federal Regulations Part 60, Subpart AAA as in effect on July 1, 1990.
 - 4. A fireplace, wood stove or other solid-fuel burning appliance which has been determined by the Maricopa County Air Pollution Control Officer to meet performance standards equivalent to those adopted by 40 Code of Federal Regulations Part 60, Subpart AAA as in effect on July 1, 1990.
 - 5. A fireplace which has a permanently installed wood stove insert which complies with subparagraphs 2, 3, or 4 above.
- (b) The following installations are not regulated by this Article and are not prohibited by this Article:
 - 1. Furnaces, boilers, incinerators, kilns, and other similar space heating or industrial process equipment.

Chapter 2 – Administration

2. Cook stoves, barbecue grills, and similar appliances designed primarily for cooking.
3. Fire pits, barbecue grills, and other outdoor fireplaces.

211.1.6 Fireplace or Wood Stove Alterations Prohibited

- (a) On or after December 31, 1998 no person, firm or corporation shall alter or remove a gas or electric log insert or a wood stove insert from a fireplace for purposes of converting the fireplace to directly burn wood or other solid fuel.
- (b) On or after December 31, 1998 no person, firm or corporation shall alter a fireplace, wood stove or other solid fuel burning appliance in any manner that would void its certification or operational compliance with the provisions of this subsection.

211.1.7 Permits Required

In addition to the provisions and restrictions of this subsection, construction, installation or alteration of all fireplaces, wood stoves and gas, electric or solid-fuel burning appliances and equipment shall be done in compliance with provisions of the County Building Code and shall be subject to the permits and inspections required by the County Building Code.

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 3 – Adoption of National Codes

SECTION 301. 2009 INTERNATIONAL BUILDING CODE

The 2009 International Building Code has been adopted as the building code for Maricopa County along with the following M.A.G. amendments:

Amendments to the 2009 International Building Code:

Revise the following Sections to read:

109.4 Work commencing before permit issuance. Any person who commences any work on a building, structure, electrical, gas, mechanical or plumbing system before obtaining the necessary *permits* shall be subject to a fee established by the Building Official that shall be in addition to the required *permit fees*. Said fee to be the building permit fee doubled.

308.2 Group I-1. This occupancy shall include buildings, structures or parts thereof housing more than 10 persons, on a 24-hour basis, who because of age, mental disability or other reasons, live in a residential environment that provides supervisory care services. The occupants are capable of responding to an emergency situation without physical assistance from staff. This group shall include, but not be limited to, the following:

- Residential board and care facilities
- Assisted living centers
- Halfway houses
- Group homes
- Congregate care facilities
- Social rehabilitation facilities
- Alcohol and drug abuse centers
- Convalescent facilities

A facility such as the above with 10 or fewer persons shall be classified as a Group R-4 Condition 1 or shall comply with the *International Residential Code* in accordance with Section 101.2 where the building is in compliance with Section 424 of this code.

308.3 Group I-2. This occupancy shall include buildings and structures used for medical, surgical, psychiatric, nursing, custodial, personal or directed care on a 24-hour basis of more than five persons who are not capable of self-preservation by responding to an emergency situation without physical assistance from staff. This group shall include, but not be limited to the following:

- Child care facilities
- Hospitals
- Nursing homes (both intermediate-care facilities and skilled nursing facilities)
- Mental hospitals

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 3 – Adoption of National Codes

Detoxification facilities

A facility such as the above with five or fewer persons shall be classified as Group R-3 or shall comply with the *International Residential Code* in accordance with Section 101.2.

This occupancy shall also include buildings and structures used for assisted living homes providing supervisory, personal, or directed care on a 24-hour basis of more than 10 persons who are not capable of self-preservation by responding to an emergency situation without physical assistance from staff. A facility such as the above with ten or fewer persons shall be classified as R-4 Condition 2.

310.1 R-4 Residential occupancies shall include buildings arranged for occupancy as residential care/assisted living homes including not more than 10 occupants, excluding staff.

310.1.1 Condition 1. This occupancy condition shall include facilities licensed to provide supervisory care services, in which occupants are capable of self-preservation by responding to an emergency situation without physical assistance from staff. Condition 1 facilities housing more than 10 persons shall be classified as a Group I-1.

310.1.2 Condition 2. This occupancy condition shall include facilities licensed to provide personal or directed care services, in which occupants are incapable of self-preservation by responding to an emergency without physical assistance from staff. Condition 2 facilities housing more than 10 persons shall be classified as Group I-2.

R-4 occupancies shall meet the requirements for construction as defined in Group R-3 except as otherwise provided for in this code, and Section 424 or shall comply with the *International Residential Code* in accordance with Section 101.2 where the building is in compliance with Section 424 of this code.

310.1 Definitions

Personal Care Service. Assistance with activities of daily living that can be performed by persons without professional skills or professional training and includes the coordination or provision of intermittent nursing services and the administration of medications and treatments.

Directed Care Service. Care of residents, including personal care services, who are incapable of recognizing danger, summoning assistance, expressing need, or making basic care decisions.

Supervisory Care Service. General supervision, including daily awareness of resident functioning and continuing needs.

Chapter 3 – Adoption of National Codes

Residential Care/Assisted Living Home. A building or part thereof housing a maximum of 10 persons, excluding staff, on a 24-hour basis, who because of age, mental disability or other reasons, live in a supervised residential environment which provides supervisory, personal, or directed services. This classification shall include, but not be limited to, the following: residential board and care facilities, assisted living homes, halfway houses, group homes, congregate care facilities, social rehabilitation facilities, alcohol and drug abuse centers and convalescent facilities.

424 Residential Care/Assisted Living Homes

424.1 Applicability. The provisions of this section shall apply to a building or part thereof housing not more than 10 persons, excluding staff, on a 24-hour basis, who because of age, mental disability or other reasons, live in a supervised residential environment which provides licensed cares services. Except as specifically required by this division, R-4 occupancies shall meet all applicable provisions of Group R-3.

424.2 General. Buildings or portions of buildings classified as R-4 occupancies shall meet all the applicable provisions of Group R-3, may be constructed of any materials allowed by this code, shall not exceed two stories in height nor be located above the second story in any building, and shall not exceed 2000 square feet above the first story except as provided in Section 506.

424.3 Special Provisions. R-4 occupancies having more than 2000 square feet of floor area above the first floor shall be of not less than one-hour fire-resistive construction throughout.

424.3.1 Mixed Uses. R-4 occupancies shall be separated from other uses as provided in Table 508.4.

424.4 Access and Means of Egress Facilities.

424.4.1 Accessibility. R-4 occupancies shall be provided with at least one accessible route per the Arizonans with Disabilities Act. Sleeping rooms and associated toilets shall be accessible.

Exception: Existing buildings shall comply with Section 3409. Bathing and toilet facilities need not be made accessible, but shall be provided with grab bars in accordance with ICC/ANSI A 117.1.

424.4.2 Exits

424.4.2.1 Number of Exits. Every story, basement, or portion thereof shall have not less than two exits.

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 3 – Adoption of National Codes

Exception: Basements and stories above the first floor containing no sleeping rooms may have one means of egress as provided in Chapter 10.

424.4.2.2 Distance to Exits. The maximum travel distance shall comply with Section 1014, except that the maximum travel distance from the center point of any sleeping room to an exit shall not exceed 75 feet.

424.4.2.3 Emergency Exit Illumination. In the event of a power failure, exit illumination shall be automatically provided from an emergency system powered by storage batteries or an onsite generator set installed in accordance with the ICC Electric Code.

424.4.2.4 Emergency Escape and Rescue. R-4 occupancies shall comply with the requirements of Section 1029, except that Exception 1 to Section 1029.1 does not apply to R-4 occupancies.

424.4.2.5 Delayed Egress Locks. In R-4 Condition 2 occupancies, delayed egress locks shall be permitted in accordance with Sections 1008.1.4.4, and items 1, 2, 4, 5 and 6, or 1008.1.9.8.

424.4 Smoke Detectors and Sprinkler Systems

424.5.1 Smoke Alarms. All habitable rooms and hallways in R-4 occupancies shall be provided with smoke alarms installed in accordance with Section 907.2.11.

424.5.2 Sprinkler Systems. R-4 occupancies shall be provided with a sprinkler system installed in accordance with Section 903.3. Sprinkler systems installed under this Section shall be installed throughout, including attached garages, and in Condition 2 facilities shall include attics and concealed spaces of or containing combustible materials. Such systems may not contain unsupervised valves between the domestic water riser control valve and the sprinklers. In R-4 Condition 2 occupancies, such systems shall contain water-flow switches electrically supervised by an approved supervising station, and shall sound an audible signal at a constantly attended location.

Add new exception to **716.5.4**

Exceptions:

4. Such walls are penetrated by ducted HVAC systems, have a required fire-resistance rating of 1 hour or less and are in buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.3.1 or 903.3.1.2. For the purposes of this exception, a ducted HVAC system shall be a duct system for conveying supply, return or exhaust air as part of the structure's HVAC system. Such a duct system shall be constructed of sheet steel not less than 26 gage thickness and shall be continuous from the air-handling appliance or equipment to the air outlet and inlet terminals.

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 3 – Adoption of National Codes

Section 903.2.8, Group R: An automatic sprinkler system installed in accordance with Section 903.3 shall be provided throughout all buildings with a Group R fire area except one and two family dwellings.

Section 1008.1.2, Door Swing. Egress doors shall be side-hinged swinging.

Exceptions:

4. Doors within or serving a single dwelling unit in Groups R-2, R-3 as applicable in Section 101.2, and R-4

Add 1101.3 as follows:

1101.3 Other Regulations: In addition to the requirements of this code all structures and sites must comply with the "Arizonans with Disabilities Act" (Arizona Revised Statutes, Title 41, Chapter 9, Article 8), and the "Arizonans with Disabilities Act Implementing Rules" (Arizona Administrative Code, Title 10, Chapter 3, Article 4). These regulations incorporate the federal "Americans with Disabilities Act Accessibility Guidelines for Buildings and Facilities". These requirements will apply to new construction and alterations and are not applicable in existing buildings or portions of existing buildings that do not meet the standards and specifications of these regulations. These regulations are hereby adopted and made a part hereof as though fully set forth in this section. Where these regulations differ from the requirements of Chapter 11 of the 2006 International Building Code, the stricter shall apply.

Revise as follows:

1210.2 Walls. Walls within 2 feet (10 mm) of service sinks, urinals and water closets shall have a smooth, hard, nonabsorbent surface, to a height of 4 feet (1219 mm) above the floor and except for structural elements, the materials used in such walls shall be of a type that is not adversely affected by moisture.

Chapter 13 Energy Efficiency is deleted in its entirety.

1503.4.4 Where Required. All roofs, paved areas, yards, courts and courtyards shall drain into a separate storm sewer system, or a combined sewer system, or to an approved place of disposal.

1503.4.5 Roof Design. Roofs shall be designed for the maximum possible depth of water that will pond thereon as determined by the relative levels of roof deck and overflow weirs, scuppers, edges or serviceable drains in combination with the deflected structural elements. In determining the maximum possible depth of water, all primary roof drainage means shall be assumed to be blocked. Design shall be based on 6" rainfall in 1 hour.

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 3 – Adoption of National Codes

1503.4.6 Overflow Drainage Required. Overflow (emergency) roof drains or scuppers shall be provided where the roof perimeter construction extends above the roof in such a manner that water will be entrapped if the primary drains allow buildup for any reason.

1503.4.6.1 Separate Systems Required. Overflow roof drain systems shall have the end point of discharge separate from the primary system. Discharge shall be above grade, in a location, which would normally be observed by the building occupants or maintenance personnel.

1503.4.6.2 Overflow Drains and Scuppers. Where roof drains are required, overflow drains having the same size as the roof drains shall be installed with the inlet flow line located 2 inches (51mm) above the low point of the roof, or overflow scuppers having three times the size of the roof drains may be installed in the adjacent parapet walls. Scuppers shall be sized to prevent the depth of ponding water from exceeding that for which the roof was designed as determined by the plumbing code. Scuppers shall not have an opening dimension of less than 4 inches (102 mm). The flow through the primary system shall not be considered when sizing the secondary roof drain system.

Table 1607.1 Revise as follows:

OCCUPANCY OR USE	UNIFORM (PSF)	CONCENTRATED (LBS.)
27. Residential One- and two-family dwellings		
Uninhabitable attics with limited storage	40	
Habitable attics and sleeping areas	40	
(no other changes in item 27)		

Section 3109 Swimming Pool Enclosures is deleted.

SECTION 302. 2009 INTERNATIONAL RESIDENTIAL CODE

The 2009 International Residential Code has been adopted as the Residential Building Code for Maricopa County along with the following M.A.G. amendments.

Amendments to the 2009 International Residential Code:

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 3 – Adoption of National Codes

Revise Table R 301.5 as follows:

Use	Live Load
Attics with limited storage ^{b,g}	40
Habitable attics and attics served with fixed stairs	40
Sleeping rooms	40

No other changes to table

Section R313 Automatic fire sprinkler systems is deleted

Chapter 11 Energy Efficiency is deleted in its entirety.

M1307.7 Liquefied Petroleum Appliances. LPG appliances shall not be installed in an attic, pit or other location that would cause a ponding or retention of gas.

M1503.1 General. Range hoods shall discharge to the outdoors through a single wall duct. The duct serving the hood shall have a smooth interior surface, shall be airtight, and shall be equipped with a backdraft damper. Changes in size or direction shall be accomplished with a pre-manufactured transition fitting. Ducts serving range hoods shall not terminate in an attic or crawl space or areas inside the building (no other changes)

G2406.2 Add new item 6 text after the exceptions as follows:

6. Liquefied Petroleum Appliances. LPG appliances shall not be installed in an attic, pit or other location that would cause a ponding or retention of gas.

G2415.10 (404.9) Minimum Burial Depth. Underground piping systems shall be installed a minimum depth of 12 inches (305 mm) below grade for metal piping and 18 inches (457 mm) for plastic piping.

SECTION G2415.10.1 Outside appliances is deleted

SECTION P2803.6.1 Requirements for discharge piping. The discharge piping serving a pressure relief valve, temperature relief valve or combination thereof shall:

1. Not be directly connected to the drainage system.
2. Discharge through an air gap located in the same room as the water heater except where the discharge is to the outdoors, not subject to freezing and the piping

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 3 – Adoption of National Codes

terminates not less than 6 inches (152mm) and not more that 12 inches (305mm) above grade.

3. Not be smaller that the diameter of the outlet of the valve served and shall discharge full size to the air gap.
4. Serve a single relief device and shall not connect to piping serving any other relief device or equipment.
5. Discharge to the floor, to the pan serving the water heater or storage tank, to a waste receptor or to the outdoors.
6. Discharge in a manner that does not cause personal injury or structural damage.
7. Discharge to a termination point that is readily observable by the building occupants.
8. Not be trapped.
9. Be installed so as to flow by gravity.
10. Not terminate more that 6 inches (152mm) above the floor or waste receptor.
11. Not have a threaded connection at the end of such piping.
12. Not have valves or tee fittings.
13. Be constructed of those materials listed in Section 605.4 or materials tested, rated and approved for such use in accordance with ASME A112.4.1.
14. Direct the discharge in a downward direction.

SECTION P2904 DWELLING UNIT FIRE SPRINKLER SYSTEMS is deleted.

SECTION 303. 2009 INTERNATIONAL MECHANICAL CODE

The 2009 International Mechanical Code has been adopted as the Mechanical Code for Maricopa County with one amendment to delete Section 301.2.

SECTION 304. 2009 INTERNATIONAL PLUMBING CODE

The 2009 International Plumbing Code has been adopted as the plumbing code for Maricopa County with two amendments.

504.6 Requirements for discharge piping. The discharge piping serving a pressure relief valve, temperature relief valve or combination thereof shall:

1. Not be directly connected to the drainage system.
2. Discharge through an air gap located in the same room as the water heater except where the discharge is to the outdoors, not subject to freezing and the piping terminates not less than 6 inches (152mm) and not more that 12 inches (305mm) above grade.
3. Not be smaller than the diameter of the outlet of the valve served and shall discharge full size to the air gap.

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 3 – Adoption of National Codes

4. Serve a single relief device and shall not connect to piping serving any other relief device or equipment.
5. Discharge to the floor, to the pan serving the water heater or storage tank, to a waste receptor or to the outdoors.
6. Discharge in a manner that does not cause personal injury or structural damage.
7. Discharge to a termination point that is readily observable by the building occupants.
8. Not be trapped.
9. Be installed as to flow by gravity.
10. Not terminate more than 6 inches (152mm) above the floor or waste receptor.
11. Not have a threaded connection at the end of such piping.
12. Not have valves or tee fittings.
13. Be constructed of those materials listed in Section 6-5-.4 or materials tested, rated and approved for such use in accordance with ASME A112.4.1.
14. Direct the discharge in a downward direction.

904.1 Roof extension All open vent pipes that extend through a roof shall be terminated at least six inches (152mm) above the roof, except that where a roof is to be used for any purpose other than weather protection, the vent extensions shall be run at least 7 feet (2134mm) above the roof.

SECTION 305. 2008 NATIONAL ELECTRICAL CODE

The 2008 National Electrical Code has been adopted as the electrical code for Maricopa County along with the following M.A.G. amendments.

Revise the following sections to read:

210-8. Ground-Fault Circuit-Interrupter Protection for Personnel

FPN: See 215.9 for ground-fault circuit-interrupter protection for personnel on feeders.

(A) All Occupancies. All 125-volt, single-phase, 15 and 20-ampere receptacles installed in the locations specified in (1) through (9) shall have ground-fault circuit-interrupter protection for personnel.

1. Bathrooms
2. Garages, and also accessory buildings that have a floor located at or below grade level not intended as habitable rooms and limited to storage areas, work areas and areas of similar use.
3. Outdoors

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 3 – Adoption of National Codes

Exception No. 1 to (3): Receptacles that are not readily accessible and are supplied by a dedicated branch circuit for electric snow-melting or deicing equipment shall be permitted to be installed in accordance with 426.28.

Exception No. 2 to (3): In industrial establishments only, where the conditions of maintenance and supervision ensure that only qualified personnel are involved, an assured equipment grounding conductor program as specified in 590.6(B)(2) shall be permitted for only those receptacle outlets used to supply equipment that would create a greater hazard if power is interrupted or having a design that is not compatible with GFCI protection.

4. Crawl Spaces – at or below grade level
5. Unfinished basements – for purposes of this section, unfinished basements are defined as portions or areas of the basement not intended as habitable rooms and limited to storage areas, work areas, and the like.

Exception to (5): A receptacle supplying only a permanently installed fire alarm or burglar alarm system shall not be required to have ground-fault circuit-interrupter protection.

FPN: See 760.41(B) and 760.121(B) for power supply requirements for fire alarm systems.

Receptacles installed under the exception to 210.8(A)(5) shall not be considered as meeting the requirements of 210.52(G).

6. Kitchens –
 - (a) Dwelling units – where the receptacles are installed to serve countertop surfaces
 - (b) Other than dwelling units – all locations
7. Sinks – where the receptacle are installed within 1.8m (6 ft) of the outside edge of the sink.

Exception No. 1 to (7): In industrial laboratories, receptacles used to supply equipment where removal of power would introduce a greater hazard shall be permitted to be installed without GFCI protection.

Exception No. 2 to (7): For receptacles located in patient care areas of health care facilities other than those covered under 210.8(A)(1), GFCI protection shall not be required.

8. Boathouses
9. Indoors:
 - (a) Damp locations

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 3 – Adoption of National Codes

(b) Wet locations

(B) Boat Hoists. GFCI protection shall be provided for outlets not exceeding 240 volts that supply boat hoists installed in dwelling unit locations.

250.118 Types of Equipment Grounding Conductors. The equipment grounding conductor run with or enclosing the circuit conductors shall be one or more or a combination of the following:

FPN: For effective ground-fault current pate, see 250.2 Definition.

1. A copper, aluminum, or copper-clad aluminum conductor. This conductor shall be solid or stranded; insulated, covered, or bare; and in the form of a wire or a busbar of any shape.
2. Rigid metal conduit.
3. Intermediate metal conduit.
4. Electrical metallic tubing with an additional equipment grounding conductor.
5. Listed flexible metal conduit with an additional equipment grounding conductor, and meeting all the following conditions:
 - a. The conduit is terminated in listed fittings.
 - b. The combined length of flexible metal conduit and liquidtight flexible metal conduit in the same ground return path does not exceed 1.8 m (6ft) for feeders and 15 m (50ft) for branch circuits.
 - c. The additional equipment grounding conductor is terminated at each termination or junction point.
6. Listed liquidtight flexible metal conduit meeting all the following conditions:
 - a. The conduit is terminated in listed fittings.
 - b. For metric designators 12 through 16 (trade sizes 3/8 through 1/2), the circuit conductors contained in the conduit are protected by overcurrent devices rated at 20 amperes or less.
 - c. For metric designators 21 through 35 (trade sizes 3/4 through 1 1/4), the circuit conductors contained in the conduit are protected of overcurrent devices rated not more than 60 amperes and there is no flexible metal conduit, flexible metallic tubing, or liquidtight flexible metal conduit in trade sizes metric designators 12 through 16 (trade sizes 3/8 through 1/2) in the grounding path.
 - d. The combined length of flexible metal conduit and flexible metallic tubing and liquidtight flexible metal conduit in the same ground return path does not exceed 1.8 m (6ft).
 - e. Where used to connect equipment where flexibility is necessary after installation, an equipment grounding conductor shall be installed.
7. Listed liquidtight flexible metal conduit with an additional equipment grounding conductor and meeting all of the following conditions:

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 3 – Adoption of National Codes

- a. The conduit is terminated in listed fittings.
- b. The combined length of liquidtight flexible metal conduit and flexible metal conduit in the same ground return path does not exceed 15 m (50ft) for branch circuits and 1.8 m (6ft) for feeders.
- c. The additional equipment grounding conductor is terminated at each termination or junction point.
8. Flexible metallic tubing where the tubing is terminated in listed fittings and meeting the following conditions:
 - a. The circuit conductors contained in the tubing are protected by overcurrent devices rated at 20 amperes or less.
 - b. The combined length of flexible metal conduit and flexible metallic tubing and liquidtight flexible metal conduit in the same ground return path does not exceed 1.8 m (6ft).
9. Armor of Type AC cable with an additional equipment grounding conductor and as provided in 320.108.
10. The copper sheath of mineral-insulated, metal-sheathed cable.
11. Type MC cable where listed and identified for grounding in accordance with the following:
 - a. The combined metallic sheath and grounding conductor of interlocked metal tape-type MC cable.
 - b. The metallic sheath or the combined metallic sheath and grounding conductors of the smooth or corrugated tube-type MC cable.
12. Cable trays as permitted in 392.3 and 392.7.
13. Cablebus framework as permitted in 370.3.
14. Other listed electrically continuous metal raceways and listed auxiliary gutters.
15. Surface metal raceways listed for grounding.

334.10 Uses Permitted. Type NM, Type NMC and Type NMS cables shall be permitted to be used in the following:

1. One-and two-family dwellings.
2. Multifamily dwellings permitted to be of Types III, IV, and V construction
3. Other dwelling unit accessory buildings and structures in accordance with 334.10 (1) and (2).

FPN No. 1: Types of building construction and occupancy classifications are defined in NFPA 220-2006, *Standard on Types of Building Construction*, or the applicable building code, or both.

FPN No. 2: See Annex E for determination of building types [NFPA 220, Table 3-1].

4. Cable trays in structures permitted to be Types III, IV, or V where the cables are identified for the use.

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 3 – Adoption of National Codes

FPN: See 310.10 for temperature limitation of conductors.

(A) Type NM. Type NM cable shall be permitted as follows:

1. For both exposed and concealed work in normally dry locations.
2. To be installed or fished in air voids in masonry block or tile walls.

(B) Type NMC. Type NMC cable shall be permitted as follows:

1. For both exposed and concealed work in dry, moist, damp, or corrosive locations.
2. In outside and inside walls of masonry block or tile.
3. In a shallow chase in masonry, concrete, or adobe protected against nails or screws by a steel plate at least 1.59 mm (1/16 in.) thick and covered with plaster, adobe, or similar finish.

(C) Type NMS. Type NMS cable shall be permitted as follows:

1. For both exposed and concealed work in normally dry locations.
2. To be installed or fished in air voids in masonry block or tile walls.

334.12 Uses Not Permitted.

(A) Types NM, NMC, and NMS. Types NM, NMC, and NMS cables shall not be permitted as follows:

1. In any dwelling or structure not specifically permitted in 334.10 (1), (2), and (3).
2. As service-entrance cable.
3. In hoistways or on elevators or escalators.
4. Embedded in poured cement, concrete, or aggregate.

(B) Types NM and NMS. Types NM and NMS cables shall not be used under the following conditions or in the following locations:

1. Where exposed to corrosive fumes or vapors.
2. Where embedded in masonry, concrete, adobe, fill or plaster.
3. In a shallow chase in masonry, concrete or adobe and covered with plaster, adobe or similar finish.
4. In wet or damp locations.

SECTION 306. 2003 INTERNATIONAL FIRE CODE

The 2003 International Fire Code has been adopted as the Fire Code only for properties owned by Maricopa County, regardless of the jurisdiction within which the property lies, along with the following amendments:

MARICOPA COUNTY LOCAL ADDITIONS & ADDENDA

Chapter 3 – Adoption of National Codes

AMENDMENTS TO THE 2003 INTERNATIONAL FIRE CODE

Delete all references to the International Existing Building Code from sections 102.3, 102.4, 102.5 and any other sections.

Revise section 104.6 to read:

104.6 Official Records. The fire code official shall keep official records as required by Sections 104.6.1 through 104.6.4. Such official records shall be retained for not less than ninety (90) days after final occupancy approval, unless otherwise provided by other regulations.

Delete Section 105 Permits.

Delete Section 107 Maintenance.

Delete Section 109.3 Violation Penalties.

Delete all Appendices A through G.

SECTION 307. 2009 INTERNATIONAL FUEL GAS CODE

The 2009 International Fuel Gas Code has been adopted as the Fuel Gas Code for Maricopa County with one amendment to delete sections 301.2 and 404.9.1, and one revision as follows:

404.9 Minimum burial depth. Underground piping systems shall be installed a minimum depth of 12 inches (305 mm) below grade for metal piping and 18 inches (457mm) for plastic piping.