



Rule 353 Clarification

An above ground storage tank (AST) installed prior to November 2, 2016, that does not currently have a spill containment receptacle installed on an AST fill pipe, is not required to install and maintain a spill containment receptacle on an AST fill pipe.

An AST installed on or after December 2, 2016 shall be equipped with a spill containment receptacle that is maintained to be free of standing liquid, debris and other foreign matter.